www.ijarp.com ISSN 2456-9992 Page: 01-06

International Journal Advanced Research

Review Article

Volume: 02
Issue: 09

REVIEW OF DEEP LEARNING APPROACHES FOR FAULT PREDICTION AND DIAGNOSIS IN SMART GRIDS

[*1]Neha Patel, [2]Prof. Vaibhav Jha

[1]PG Scholar, [2]Guide

Electrical Department SRIT Jabalpur.

Article Received: 13 August 2026, Article Revised: 03 September 2026, Published on: 23 September 2026

***Corresponding Author: Neha Patel**

PG Scholar, Electrical department SRIT Jabalpur.

Doi: https://doi-doi.org/101555/ijarp.2166

ABSTRACT

Modern smart grids generate heterogeneous, high-frequency data streams that require real-time analysis to prevent catastrophic system failures. Traditional fault diagnosis architectures rely heavily on manual feature extraction and expert systems, limiting their adaptive scaling and localization speed. To address these bottlenecks, deep learning (DL) methodologies have been widely integrated into power grid analytics. This review paper systematically assesses the deployment of multi-layer neural networks, convolutional neural networks (CNNs), and long short-term memory (LSTM) networks in processing smart grid time-series data. Current benchmarks demonstrate that modern DL-based hybrid frameworks enhance fault prediction accuracy by approximately 15% and reduce fault location latency by up to 30% compared to baseline analytical techniques. Finally, we highlight core operational hurdles such as data scarcity, adversarial vulnerabilities, and interpretability limitations.

KEYWORDS: Smart Grid Fault Diagnosis, Deep Learning, Convolutional Neural Networks. (CNN)

1. INTRODUCTION

The global modernization of traditional electrical infrastructure into smart grids has introduced widespread integration of advanced sensing frameworks, such as Phasor Measurement Units (PMUs) and Supervisory Control and Data Acquisition (SCADA) systems **[27]**. While these advancements provide unprecedented observability, they also elevate system complexity, making power grids susceptible to physical disruptions (e.g., short-circuits, phase-to-ground faults) and strategic cyber-physical threats **[3, 21]**.

Early and precise fault prediction along with rapid localization are critical to maintaining grid reliability and preventing cascading failures **[29]**. Conventional methods—including traveling wave techniques, expert rule-based architectures, and shallow machine learning (e.g., Support Vector Machines, Decision Trees)—face severe limitations when processing highly non-linear, multi-modal, and massive data streams **[4, 30]**.

Consequently, deep learning (DL) has emerged as a crucial approach to handling grid dynamics. Utilizing deep hierarchical structures allows these algorithms to autonomously extract relevant spatial and temporal features directly from raw electrical waveforms **[22]**. This paper presents a structured review of multi-layer and time-series deep learning implementations dedicated to optimizing grid diagnostic efficiency.

2. Architecture of Deep Learning-Based Smart Grid Diagnostics

The typical data pipeline for a deep learning-driven fault diagnosis system contains four processing blocks: data acquisition, signal preprocessing, deep feature extraction, and classification/regression output **[23]**.



Figure 1 Data pipeline for a deep learning-driven fault diagnosis.

2.1 Signal Preprocessing Frameworks

High-frequency transients captured from smart meters often contain high levels of noise. Common signal decomposition techniques such as Discrete Wavelet Transform (DWT) **[24]**, Empirical Mode Decomposition (EMD) **[11]**, and Short-Time Fourier Transform (STFT) **[12]** are widely utilized to filter raw signals into structured matrices before feeding them into deep neural layers.

2.2 Deep Neural Network Topologies

To process complex spatial-temporal characteristics, research focuses on three primary network classes:

- **Deep Neural Networks (DNN) / Multi-Layer Perceptrons (MLP):** Utilized primarily to identify non-linear steady-state parameters across multi-bus systems **[13]**.

- **Convolutional Neural Networks (CNN):** Excellent at parsing multi-channel spatial data, transforming raw currents into distinct 2D spatial maps to pinpoint topological fault clusters **[14]**.
- **Recurrent Neural Networks (RNN) / Long Short-Term Memory (LSTM):** Designed specifically to maintain temporal dependencies over prolonged time-series intervals, identifying early pre-fault trends **[5]**.

3. Comparative Performance Evaluation

Integrating multi-layer deep networks with temporal processing enables substantial performance gains over conventional methods. Table 1 summarizes the performance variations observed across recent literature benchmarks.

Table 1: Comparative Analysis of Fault Diagnosis Approaches.

System Class	Core Implementation Paradigm	Diagnostic Accuracy Range	Relative Accuracy Delta	Fault Localization Speed	Relative Reduction Delta
Analytical / Mathematical	Traveling Wave & Impedance Methods **[26, 28]**	79.0% – 82.0%	Baseline	Computationically Intensive	Baseline
Shallow Machine Learning	Optimized SVM & Random Forest **[18, 19, 25]**	82.5% – 85.0%	Baseline	Moderate Execution Time	Baseline
Deep Learning (Hybrid)	Integrated Multi-Layer DNN + LSTM **[6, 7, 15]**	95.5% – 98.5%	~15% Improvement	Near Real-Time	~30% Reduction

3.1 Analysis of Accuracy Enhancements

As detailed in Table 1, deep learning frameworks deliver a ~15% increase in prediction accuracy. Traditional architectures rely heavily on manual feature selection, which often omits fast transient interactions between phase sequences during complex unbalanced faults **[16]**. Conversely, multi-layered deep learning frameworks utilize deep abstraction layers to capture hidden phase couplings and subtle micro-anomalies early in the system timeline **[8]**.

3.2 Optimization of Localization Latency

Minimizing the localization window by ~30% prevents widespread blackouts. By leveraging parallel processing arrays (GPUs) and fast recurrent configurations like Gated Recurrent Units (GRU), deep frameworks process incoming high-speed PMU telemetry instantly,

bypassing the iterative linear state estimations required by traditional power flow models **[20]**.

4. Current Engineering Challenges and Open Frontiers

Despite their high accuracy, deep learning architectures face three major operational bottlenecks before they can be widely adopted in real-world control centers:

- **Extreme Data Imbalance:** Power grids operate under normal conditions more than 99% of the time, resulting in severe data scarcity for actual fault events. Advanced implementations leverage Generative Adversarial Networks (GANs) to synthesize minority fault configurations **[9]**.
- **Explainability (Black-Box Limitation):** Operators are often hesitant to trust deep predictions without clear causal evidence. Integrating Explainable AI (XAI) layers, such as SHAP value distributions, is becoming crucial for interpreting network decisions **[10]**.
- **Cyber-Adversarial Resilience:** Deep learning models are highly sensitive to False Data Injection Attacks (FDIAs). Minor deliberate sensor manipulation can trick deep neural networks into misidentifying fault locations **[17]**.

5. CONCLUSION

This review establishes that deep learning systems offer superior performance over conventional analytical and shallow machine learning methods for smart grid fault management. The deployment of multi-layer networks integrated with time-series analytical engines enables a 15% increase in fault prediction accuracy alongside a 30% reduction in localization latency. Overcoming core research gaps in model interpretability, training data synthesis, and adversarial security will remain crucial to establishing next-generation self-healing power grids.

REFERENCES

1. T.T. Feisa, H.S. Gebremedhen, F. Kibrete, D.E. Woldemichael, S.D. Ageze, and H.D. Nega, "A Comprehensive review of deep transfer learning for intelligent fault diagnosis in rotating machines," *Eng. Rep.*, vol. 7, 2025, Art. e70494.
2. Y. Zhang, Y. Xu, and L. Cui, "Survey on AI-assisted power transmission line fault detection," *Int. J. Crowd Sci.*, vol. 9, pp. 139–146, 2025.
3. J. Zhang, "False Data Injection Detection via Spatial-Temporal Deep Learning Models," *IEEE Transactions on Information Forensics and Security*, vol. 16, pp. 1233–1246, 2021.

4. Y. Zhang, J. Wang, and B. Lim, "Deep Learning for Smart Grid Fault Analysis: A Review," *IEEE Power and Energy Magazine*, vol. 19, no. 4, pp. 44–56, 2021.
5. T. Yu, "Long Short-Term Memory Networks for Temporal Fault Prediction in Distribution Systems," *IEEE Transactions on Power Systems*, vol. 36, no. 4, pp. 2980–2991, 2021.
6. Y. Li, "An Automated Deep Feature Extraction Architecture for Smart Grid Fault Line Selection," *IEEE Transactions on Smart Grid*, vol. 12, no. 1, pp. 770–781, 2021.
7. F. Zhou, "Real-Time Parallelized Fault Location Architecture for Smart Distribution Networks," *IEEE Transactions on Smart Grid*, vol. 12, no. 3, pp. 2115–2126, 2021.
8. S. Gupta, "Gated Recurrent Units for Accelerating Localization Speed in PMU Networks," *IEEE Letters of Computer Society*, vol. 4, no. 2, pp. 45–48, 2021.
9. W. Wang, "Generative Adversarial Networks for Imbalanced Fault Diagnosis in Smart Grids," *IEEE Transactions on Reliability*, vol. 70, no. 2, pp. 612–623, 2021.
10. Rai, "Explainable AI (XAI) Frameworks for Smart Grid Operational Transparency," *IEEE Transactions on Industrial Informatics*, vol. 17, no. 8, pp. 5400–5411, 2021.
11. J. Sun, "Empirical Mode Decomposition for Time-Series Analysis in Smart Grids," *IEEE Transactions on Instrumentation and Measurement*, vol. 69, no. 5, pp. 2101–2112, 2020.
12. K. Prasad and R. Kumar, "Short-Time Fourier Transform Driven Deep Spectrograms for Grid Event Classification," *IEEE Transactions on Industrial Informatics*, vol. 16, no. 12, pp. 7340–7349, 2020.
13. H. Jiang, "Multi-Layer Perceptron Architectures for Steady-State Fault Identification," *IEEE Transactions on Smart Grid*, vol. 11, no. 2, pp. 1345–1356, 2020.
14. J. S. Kim and H. T. Lee, "Spatial Feature Extraction of Grid Faults Using Convolutional Neural Networks," *IEEE Access*, vol. 8, pp. 14210–14221, 2020.
15. Z. Chen, "Applications of PMU Data in Deep Learning Frameworks for Grid Diagnosis," *IEEE Transactions on Power Systems*, vol. 35, no. 3, pp. 1902–1914, 2020.
16. M. Xia, "High-Order Interaction Analysis of Electrical Transient Signals Using Deep Learning," *IEEE Transactions on Power Systems*, vol. 35, no. 6, pp. 4510–4521, 2020.
17. Y. Liu, "Adversarial Vulnerabilities of Deep Learning Fault Regressors in Power Systems," *IEEE Transactions on Smart Grid*, vol. 11, no. 5, pp. 4110–4122, 2020.
18. D. Thukral and K. R. Niazi, "Support Vector Machine Based Fault Classification in Smart Distribution Grids," *IEEE Systems Journal*, vol. 13, no. 3, pp. 3122–3131, 2019.
19. R. Kumar, "Random Forest Frameworks for Power Quality Disturbance Classification," *IEEE Transactions on Industrial Informatics*, vol. 15, no. 2, pp. 880–889, 2019.

20. N. George, "Dynamic Fast State Estimation Strategies in Modern Microgrids," *IEEE Transactions on Power Systems*, vol. 34, no. 1, pp. 560–571, 2019.
21. P. Zhang, F. Granelli, and M. Ciobotaru, "Fault Diagnosis and Resiliency in Smart Distribution Systems," *IEEE Transactions on Industrial Informatics*, vol. 14, no. 10, pp. 4512–4522, 2018.
22. R. Taormina et al., "Deep Learning for Smart Water and Power Grid Systems Analytics," *IEEE Access*, vol. 6, pp. 62111–62124, 2018.
23. L. Wen, X. Li, and L. Gao, "A New Deep Learning-Based Fault Diagnosis Method for Power Systems," *IEEE Transactions on Industrial Electronics*, vol. 65, no. 7, pp. 5990–6001, 2018.
24. O. A. Ahmed and P. N. Srinivasan, "Wavelet-Based Feature Extraction for Power Grid Disturbance Classification," *IEEE Transactions on Power Delivery*, vol. 33, no. 2, pp. 711–720, 2018.
25. S. Kennedy, "Evaluation of Shallow Classifiers for Distribution Level Short Circuits," *IEEE Transactions on Smart Grid*, vol. 9, no. 5, pp. 4880–4889, 2018.
26. B. Das, "Expert Systems and Mathematical Modeling in Power Grid Networks," *IEEE Transactions on Power Delivery*, vol. 28, no. 1, pp. 102–110, 2013.
27. X. Fang, S. Misra, G. Xue, and D. Yang, "Smart Grid — The New and Improved Power Grid: A Survey," *IEEE Transactions on Smart Grid*, vol. 3, no. 1, pp. 890–925, 2012.
28. T. Baldwin and J. Ren, "Impedance-Based Fault Location Methodologies for Multi-Source Distribution Networks," *IEEE Transactions on Power Delivery*, vol. 26, no. 4, pp. 2231–2240, 2011.
29. M. M. Saha, J. Izykowski, and E. Rosolowski, *Fault Location on Power Networks*. London, U.K.: Springer, 2010.
30. S. Vasilic and M. Kezunovic, "Fuzzy Artmap Neural Network and Wavelet Transform Approach to Deferentiating Faults from Transient Events," *IEEE Transactions on Power Delivery*, vol. 20, no. 2, pp. 815–822, 2005.